

EU Type Examination Certificate

This is to certify that:

Ansell Healthcare Europe NV
Boulevard International 55
B-1070 Brussels
Belgium

Holds Certificate Number:

CE 708572

In respect of:

**Electrician/Live Working - Electrical Insulating Gloves/Mitts to EN 60903:2003.
Classes 00, 0, 1, 2, 3 and 4. See continuation sheet for details.**

on the basis that BSI carried out the relevant Type Examination procedures under the requirements with the Regulation (EU) 2016/425 of the European Parliament and Council relating to Personal Protective Equipment Regulation (PPE) Annex V (Module B) and meets the relevant health and safety requirements specified in Annex II

For and on behalf of BSI, a Notified Body for the above Regulation (Notified Body Number 2797):

Previous Notified Body: BSI 0086

First Issued: 2019-04-09

Latest Issue: 2019-09-12



Drs. Dave Hagenaaers, Managing Director

Effective Date: 2019-09-12

Expiry Date: 2024-04-09

Page: 1 of 9



...making excellence a habit.™

EU Type Examination Certificate

No. CE 708572

Product Specification

Models:	Electrician / Live working – Electrical Insulating Gloves / Mitts
Classification:	Live working glove of insulating material for the protection of the worker against electrical hazards.
Description:	A range of 6 classes of gloves 00, 0, 1, 2, 3, and 4 made from natural rubber and elastomeric compounds with specific product details below.
Technical Specifications:	EN 60903:2003 - Live working. Gloves of insulating material. EN 420:2003+A1:2009 - Protective gloves. General requirements and test methods.
Class 00	
Product Standard:	EN 60903:2003 - Live working. Gloves of insulating material.
AC Maximum Operating Voltage:	500V
Special Properties:	A – acid resistance Z – ozone resistance C – extremely low temperature resistance
Size range:	8, 9 , 10 and 11
Length:	280mm or 360mm
Cuff type:	Rolled Cuff or Straight Cuff
pH value:	5 – 8.5
Dexterity:	Level 5
Extractable proteins:	<50µg/g

First Issued: 2019-04-09
Latest Issue: 2019-09-12

Effective Date: 2019-09-12
Expiry Date: 2024-04-09

Page: 2 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Product Specification (continued)

Models: Electrician / Live working – Electrical Insulating Gloves / Mitts

Class 0

Product Standard: EN 60903:2003 - Live working. Gloves of insulating material.

AC Maximum Operating Voltage: 1000V

Special Properties:
A – acid resistance
Z – ozone resistance
C – extremely low temperature resistance

Size range: 8, 9 , 10 and 11

Length: 280mm; 360mm or 410mm

Cuff type: Rolled Cuff or Straight Cuff

pH value: 5 – 8.5

Dexterity: Level 5

Extractable proteins <50µg/g



First Issued: 2019-04-09

Latest Issue: 2019-09-12

Effective Date: 2019-09-12

Expiry Date: 2024-04-09

Page: 3 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Product Specification (continued)

Models: Electrician / Live working – Electrical Insulating Gloves / Mitts

Class 1

Product Standard: EN 60903:2003 - Live working. Gloves of insulating material.

AC Maximum Operating Voltage: 7500V

Special Properties:
A – acid resistance
Z – ozone resistance
C – extremely low temperature resistance

Size range: 8, 9 , 10 and 11

Length: 360mm or 410mm

Cuff type: Rolled Cuff or Straight Cuff

pH value: 5 – 8.5

Dexterity: Level 3

Extractable proteins: <50µg/g



First Issued: 2019-04-09

Latest Issue: 2019-09-12

Effective Date: 2019-09-12

Expiry Date: 2024-04-09

Page: 4 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Product Specification (continued)

Models: Electrician / Live working – Electrical Insulating Gloves / Mitts

Class 2

Product Standard: EN 60903:2003 - Live working. Gloves of insulating material.

AC Maximum Operating Voltage: 17000V

Special Properties: A – acid resistance
H – oil resistance
Z – ozone resistance
C – extremely low temperature resistance
or
R – acid, ozone and oil resistance
C – extremely low temperature resistance

Size range: 8, 9 , 10 and 11

Length: 360mm or 410mm

Cuff type: Rolled Cuff or Straight Cuff

pH value: 5 – 8.5

Extractable proteins: <50µg/g

First Issued: 2019-04-09

Latest Issue: 2019-09-12

Effective Date: 2019-09-12

Expiry Date: 2024-04-09

Page: 5 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Product Specification (continued)

Models: Electrician / Live working – Electrical Insulating Gloves / Mitts

Class 3

Product Standard: EN 60903:2003 - Live working. Gloves of insulating material.

AC Maximum Operating Voltage:

26500V

Special Properties:

A – acid resistance
H – oil resistance
Z – ozone resistance
C – extremely low temperature resistance
or
R – acid, ozone and oil resistance
C – extremely low temperature resistance

Size range:

9, 10 and 11

Length:

360mm or 410mm

Cuff type:

Rolled Cuff or Straight Cuff

pH value:

5 – 8.5

Extractable proteins

<50µg/g



First Issued: 2019-04-09

Effective Date: 2019-09-12

Latest Issue: 2019-09-12

Expiry Date: 2024-04-09

Page: 6 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Product Specification (continued)

Models: Electrician / Live working – Electrical Insulating Gloves / Mitts

Class 4

Product Standard: EN 60903:2003 - Live working. Gloves of insulating material.

AC Maximum Operating Voltage: 36000V

Special Properties: A – acid resistance
H – oil resistance
Z – ozone resistance
C – extremely low temperature resistance
or
R – acid, ozone and oil resistance
C – extremely low temperature resistance

Size range: 9, 10, 11 and 12

Length: 410mm or 460mm

Cuff type: Rolled Cuff or Straight Cuff

pH value: 5 – 8.5

Extractable proteins <50µg/g

First Issued: 2019-04-09

Latest Issue: 2019-09-12

Effective Date: 2019-09-12

Expiry Date: 2024-04-09

Page: 7 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Certificate Administration Details.

Technical File Reference: Electrician / Live working – Electrical Insulating Gloves / Mitts to EN 60903.


Certificate Amendment Record

Issue date	Comments	BSI Internal Project No.
April 2019	First issue. Transition from PPE Directive 89/686 certificate CE 619833.	0086:19:9738786

Note: The Certificate holder is responsible for keeping the Notified Body advised of changes to any aspect of the overall process used in the manufacture of the product.

Monitoring of manufactured PPE.

The EC Quality of Production by Monitoring requirements, Module D, for the product are referenced in BSI issued certificate number CE 01450.



First Issued: 2019-04-09
Latest Issue: 2019-09-12

Effective Date: 2019-09-12
Expiry Date: 2024-04-09

Page: 8 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.

EU Type Examination Certificate

No. CE 708572

Location

Ansell Industrial & Specialty Gloves
Malaysia Sdn. Bhd.
P.O.Box 7
1A & 1B, Lorong Perusahaan 1
Kulim Industrial Estate
Kulim
Kedah
09000
Malaysia

Certified Activities

Electrician/Live Working - Electrical Insulating Gloves/Mitts to EN 60903:2003.
Classes 00, 0, 1, 2, 3 and 4. See continuation sheet for details.



First Issued: 2019-04-09

Latest Issue: 2019-09-12

Effective Date: 2019-09-12

Expiry Date: 2024-04-09

Page: 9 of 9

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.